Short-Course

Solar PV System Installation and Maintenance NTQF Level IV

Learning Guide -10

Unit of	Calculating System
Competence	Components
Module Title	Calculating System
	Components
LG Code	EIS PIM4 M01 0120 LO6-LG10
TTLM Code	EIS PIM4 TTLM 0120v1

LO 6: Balance of System-10









Instruction Sheet	Learning Guide:- 10

This learning guide is developed to provide you the necessary information, knowledge, skills and attitude regarding the following content coverage and topics:

- Determining and calculating size of wires and protection devices, low voltage disconnectors, Kilowatt Hour meter and battery meter;
- Detecting and documenting technical problems;
- Completing and reporting the work.

This guide will also assist you to attain the learning outcome stated in the cover page. Specifically, upon completion of this Learning Guide, you will be able to:-

- Determine and calculate size of wires and protection devices, low voltage disconnectors, Kilowatt Hour meter and battery meter;
- Detect and document technical problems;
- Complete and reporting the work.

Learning Instructions:

- 1. Read the specific objectives of this Learning Guide.
- 2. Follow the instructions described below:
- 3. Read the information written in the information Sheet 1 (page: 107), Sheet 2 (page: 123), Sheet 3 (page: 129)
- 4. Accomplish the Self-Check 1 (page: 121), Self-Check 2 (page: 128), Self-Check 3 (page: 136)









LO 6:- Balance of System

Information Sheet 1	Determining and calculating size of wires and protection devices, low voltage disconnectors,
	Kilowatt Hour meter and battery meter

1 Determining and calculating size of wires and protection devices, low voltage disconnectors, Kilowatt Hour meter and battery meter

1.1 Introduction

The last step in the design process is to determine the balance of system (BOS):



Figure 63: Design Step 6

In an electrical system, voltage drops can be excessive if the wires are not sized correctly. This is due to the resistance of the wires being too high. There is always a compromise between wire size and cost. Thicker wires are more expensive, but the











losses will be lower (smaller battery, panels etc.). Thinner wires will be cheaper but more losses mean bigger batteries and panels. Furthermore, cables should be kept as short as possible (specifically cables carrying high current).

Power losses in cables can be calculated using the power formula:

$$P = I^2 R$$

Where

- P= power loss in cable;
- I = the current flowing in the cable
- R= the resistance of the cable

Figure 64 indicates that the power loss (with a linear increase in current) is not linear. The higher the current the higher the losses, therefore it is important to keep the resistance as low as possible where high currents are flowing.

Protection devices need to be of the correct size and type to ensure that is protects the system adequately. For the low voltage DC system, the typical points of protection/disconnection are (refer to Figure 65):

- Fuses between the PV modules and the combiner box (F1)
- A DC Disconnect switch between the combiner box and the charge controller (S1)
- A Fuse between the Charge Controller and the batteries (F2);
- Between the batteries and the inverter (F3);

The protection and disconnection on the AC side is normally governed by specific standards and needs to be implemented by qualified electricians.



Figure 64: Power losses vs. current increase













Figure 65 - Protection and Wiring

The selection of the correct cables, fuses and accessories for electrical distribution systems can only be discussed in general terms here. National wiring codes and regulations as well as equipment manuals need to be complied with.

1.2 Calculate cable sizes

The following paragraph(s) are adapted from (Dobelmann & Klauss-Vorreiter, 2009) chapter 6.

The formula that can be used for cable sizing is the following:

$$A = \frac{L x P}{p_{loss} x V^2 x K}$$

Where

A = cross section of cable in mm²

- L = length of cable (conductor positive and negative) one way length x 2
- P = Power of the cable
- ploss = Loss factor (0.01 for 1%, 0.02 for 2% etc.)

V = system voltage

κ = Kappa – electric conductivity

 $K_{Cu} = 56 \text{ m} / \Omega \cdot \text{mm}^2 \text{ for copper}$

 $K_{Alu} = 34 \text{ m} / \Omega \cdot \text{mm}^2$ for aluminium

In practice, one can make use of tables supplied by wire manufacturers to 'lookup' the size of wires. These tables are often specified per system voltage e.g. 12V, 24V etc. In Figure 66 below, we can select the wire suitable for an appliance that consumes 30W and is 3m away from the battery. It can be seen that a 1.5mm² will be suitable.



In fact, 1.5mm² will be suitable up to 8m after which the next size (2.5mm²) will have to be used.

The Watts or Amperes listed on an appliance is its electricity use while in normal, continuous operation. For example, a refrigerator may show a power requirement of 60 Watts at 12Volts. That means when it is running continuously, it will need to receive 5 Amperes of current from the battery.

Electric motors, however, require extra current to start, several times the Amperes it uses when running. To prevent a large voltage drop, wires running to appliances with motors (refrigerators, washers and pumps for example) should be sized for at least twice as many Watts or Amperes as the appliance normally requires when running.

L	.oad	Wire	Length	In N	eters											
Watte	Amnoros	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
Walls	Amperes	Stand	ard Siz	e Wir	Needeo	d (Squa	re Milli	neters)	-	-	-		-			
5	0.42	1.5	1.5	· .{	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
10	0.83	1.5	1.5		1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
15	1.25	1.5	1.5		1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5
20	1.67	1.5	1.5		1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	2.5	2.5	2.5
25	2.08	1.5	1.5		1.5	1.5	1.5	1.5	1.5	1.5	2.5	2.5	2.5	2.5	2.5	2.5
30 -	2.50	1.5	1.5	1.5	1.5	1.5	1.5	1.5	1.5	2.5	2.5	2.5	2.5	2.5	4	4
35	2.92	1.5	1.5	1.5	1.5	1.5	1.5	2.5	2.5	2.5	2.5	2.5	4	4	4	4
40	3.33	1.5	1.5	1.5	1.5	1.5	1.5	2.5	2.5	2.5	2.5	4	4	4	4	4

Figure 66: Using a wire table

1.2.1 Type of wire

It is important to use the correct wire suitable for the application. The wire from the PV modules is exposed to the elements and needs to be PV rated wire. PV rated wire normally have the following properties:

- Mechanical stability to withstand compression, tension and bending;
- Weather stability including UV and ozone stability, heat and cold stability;
- Ground and short circuit insulation single cable with double insulation.













Figure 67 - PV1-F Cable

PV cable has different voltage and temperature ranges. Figure 68 show a selection of PV cables available with their temperature and voltage ranges and size.

Module Cables for Outdoors	Producer	Nominal Voltage in U/U ⁰	Temperature Range	Cro	Cross section diameters (mm ²)		ers	
Lapptherm Solar Plus	Lapp-Kabel	900/1500 V	-50°C – 120 °C	2,5	4	6	10	
Flex-Sol	Multi-C	600/1000 V	-40°C – 90 °C	2,5	4	6		
Radox 125	Huber+Suhner	600/1000 V	-25°C – 125 °C	2,5	4	6		
Siemens-Solar leitung	Siemens AG	1800/3000 V	-40°C – 120 °C	2,5	4	6		
Solar-Kabel*C	Solar-Kabel GmbH	1800/3000 V	-25°C – 90 °C	2,5	4	6		
Solarflex 101	Helukabel GmbH	600/1500 V	-30°C – 125 °C	2,5	4	6	10	16
TECSUN S1ZZ-F Solarleitung	Pirelli Kabel und Systeme GmbH	900/1800 V	-40°C – 120 °C	2,5	4	6	10	
Titanex 11 H07RN-F	ConCab-Kabel	450/750 V	-35°C – 85 °C	2,5	4	6		

Figure 68: PV Cable comparison

Although the size of the wire is the most basic specification, there are several different types of wire available in standard sizes. Typically, wire is classified as multi-stranded or solid. For house wiring, solid copper wire is often used. It consists of a single solid copper conductor inside an insulating sleeve (figure Figure 69b). Solid wires are usually cheaper but are stiff and if bent back and forth enough times they will break.











Figure 69: Conductor types

Often wire is made up of many small wires all bunched together inside the insulating sleeve. It is called stranded wire because it is made up of many small strands of wire (Figure 69a). Though each strand is very small, enough strands are bunched together to make the total wire area equal to that of a solid wire. For example, if each strand is , 0.1 mm² in size, then 25 strands will be used in a 2.5 mm² wire. The main advantage of stranded wire is its flexibility. Electrically, there is no difference between equal sizes of stranded and solid wire. Solid wire is cheaper and good for permanent installations. Stranded wire is usually best for any application where the wire is not permanently fixed in place.

1.3 Fuses and circuit breakers

The following paragraph(s) are taken/adapted from (Hankins, 2010) chapter 7.

Fuses are sized according to the current through the fuse and the voltage over the fuse. Temperature can also de-rate fuses.

Fuses are devices placed in circuits to prevent accidental damage to appliances, modules and charge-controller circuitry from high current normally associated with short circuits. The very high current that batteries will deliver under short circuit conditions can cause fires, extensive damage or even explosions! Ideally, in a system, there should be a fuse on each of the battery, solar array and load circuits.

When a short circuit occurs or there is an overload, the fuse 'blows' (i.e. a strip of wire inside melts). This opens the circuit so that current cannot flow. Once a fuse has blown, the cause of the high current should always be investigated and repaired before replacing the fuse with a new one of the same rating.

Miniature circuit breakers (MCBs) are small switches that automatically break the circuit when there is a short circuit or overload. Unlike fuses, they can be switched back on once the wiring problem has been corrected.

DC-rated fuses and circuit breakers should be used in DC circuits, and AC-rated fuses and circuit breakers should be used in AC circuits. They also need to be correctly rated for the circuit voltage.

As a minimum safety precaution, all small systems (less than 100Wp) require at least one fuse: the main battery fuse. Larger systems should have a fuse to protect each











major circuit, the battery and the module/array. If there are loads that need to be protected independently, then fuses should be included in the circuit of that load.

Some charge controllers contain in-built electronic load and circuit protection. Look for these charge controllers that have circuitry to protect loads and PV arrays. Such charge controllers not only avoid the problem of including multiple fuses, they also avoid the common (and very dangerous!) practice of consumers replacing blown fuses with the wrong-sized fuse wire (or pieces of copper /tools – see Figure 70).

In all cases, when planning fuse protection, choose the main battery fuse first and follow these suggestions:

- The fuse should be DC rated.
- It should be on the positive cable(s) from the battery, as near as possible to the battery's positive terminal in unearthed and in negative earthed-systems, which most systems are.
- Its rating in amperes (A) should be less than the thermal rating (current rating) of the battery cables. A 30A fuse protecting a cable designed to take 20A means that if 29A flows in the cable the fuse will not blow – but the cable, which is designed to take a maximum of 20A, will overheat and become a fire hazard. However, a 15A fuse would provide full protection.
- Its 'breaking capacity' (in kA) should be greater than the battery short circuit current. This means that the fuse needs to be able to blow (i.e. not arc) if there is a short circuit short-circuit currents can be very high.



Figure 70: Dangerous fuse 'replacement'

Other fuses (often located in the charge controller) are important but do not protect against battery short circuit from faults in cables between the battery and the charge controller. Refer to the inverter manual when placing fuses on inverter circuits. It should specify fuse size and type (as well as recommended cable size from battery to inverter).





Figure 71: Battery DC-rated fuses

1.3.1 Battery Fuse Calculation

Fuses are rated in amps. They are sized to 'blow' very quickly when the current is about 20 % greater than the maximum expected current in the circuit. If, for example, there is a short circuit in one of the appliances, the circuit draws much more than the rated current (i.e. more than 20 per cent higher), so the fuse rapidly heats up, 'blows' very quickly and opens the circuit.

To size the battery fuse calculate the power of the loads (W) and divide it by the system voltage to get current (A). Take this current and multiply with 1.2 to get the fuse current rating.

1.3.2 PV Fuse calculation

PV Fuses are often use when there are multiple strings combined. An earth fault in one string can cause the other string currents to also flow into the earth fault. PV strings are normally calculated empirically as follows:

- V_{P,fuse} ≥ V_{OC,array} x 1.2
- Inom,fuse ≥ ISC module x 1.4

As an example, if there are a string of 4 modules (V_{OC} = 36V), and the Short circuit current I_{SC} = 10A:

- V_{P,fuse} ≥ V_{OC,array} x 1.2 ≥ (4 modules x 36V) x 1.2 ≥ 172.8V
- $I_{\text{nom,fuse}} \ge I_{\text{SC module}} \ge 1.4 \ge 10A \ge 1.4 \ge 14A$

From the fuse datasheet (Figure 72), the closest suitable fuse will be the PV-15A10F fuse.











Product Code	Rated Current	Rated Voltage	Breaking Capacity	Dimensions	Class
PV-2A10F	2A	600V DC	30kA	10 x 38mm	gPV
PV-6A10F	6A	600V DC	30kA	10 x 38mm	gPV
PV-8A10F	8A	600V DC	30kA	10 x 38mm	gPV
PV-10A10F	10A	600V DC	30kA	10 x 38mm	gPV
PV-124107	12A	BOOV DC	30kA	10 x 38mm	gPV
PV-15A10F	15A	600V DC	30kA	10 x 38mm	gPV
PV-20A10F	20A	600V DC	30kA	10 x 38mm	gPV
PV-25A10F	25A	600V DC	30kA	10 x 38mm	gPV

10 x 38 PV Fuses (1000V DC)

Figure 72: PV Fuse selection

1.4 Switches

Switches are used to turn appliances and other loads on and off. They also serve the important purpose of disconnecting modules, batteries and loads during servicing and emergencies. Always select the right type and size of switch for the purpose.

Switches and disconnects need to be properly rated for the circuit in which they are being installed – in terms of current and voltage. A switch or disconnect in a 12V DC circuit needs to be rated for 12V DC and the maximum current expected in that circuit, while a switch or disconnect in a 230V AC circuit needs to be rated for 230V AC and the maximum current expected in that circuit. Many switches and disconnects are rated for both DC and AC current/voltage, though the values for AC and DC may be different. When 230V AC switches must be used to turn lights or small appliances on and off (e.g. because suitable 12V DC switches are not available, which is often the case) always make sure that their nominal current rating is twice the maximum expected DC current.

Only use the proper DC-type switches of the correct voltage and current rating on main switches that control high current DC appliances, PV array or battery circuits. Improperly used AC switches may burn up or arc, and may cause dangerous short circuits or fires!

1.5 Meter selection

Some manufacturers may have built-in meters in their inverters and charge controllers while others may have external devices that communicate with the devices and report the state of charge, power consumption etc. either to the internet or to a local display unit.

Figure 73 shows the use of an ammeter and voltmeter connected between the load and the charge controller. In this case, the ammeter will act as a rev counter (the higher



the current, the higher the motor revolutions) while the voltmeter will report the battery voltage (fuel gage).



Figure 73: Adding meters to an Off-Grid system (Boxwell, 2017)

In Figure 74 a Charge Controller with built-in meter can be seen.



Figure 74: Charge Controller Integrated Meter

Figure 75 shows a separate display unit that can communicate with charge controllers and inverters. It may also provide remote access via the internet.



Figure 75: Separate Display Unit

In larger systems, it is often advisable to include a battery monitor (Figure 76 and Figure 77) device between the charge controller and the inverter. While the charge controller controls the charging of the battery, the battery monitor protects the battery to make sure it is not discharged too deeply.





Figure 76: System with battery monitor



Figure 77: Battery Monitor

1.5.1 Adama design

In reference to the Adama design Figure 78, we need to calculate the following:

Cabling	L Single Distance	LF Loss Factor	P _{max} Affiliated Power	K Condu ctivity	U _{SYS} System Voltage
A1 Single Cable Length between Modules and combiner box (Vmpp, String) per string	5 m	1.0%	4900 W/2 strings 2450W per string	56	270.2 V
A2 Single Cable Length between combiner box and charge Controller (Vmpp, String)	5 m	1.0%	4900 W	56	270.2 V
A3 Single Cable Length between Charge Controller and Battery (PPV)	3.00 m	0.50%	4900 W	56	48 V
Material of the Cables	Cu				

Required cable diameters $A = \frac{L \times P}{0.03 \times U^2 \times k}$

 $A1 = \frac{2 \times 5 \ m \ \times \ 2450W}{0.001 \times 270.2^2 \times 56} = 0.6 \ \text{mm}^2 \text{, selected diameter 4 mm}^2 \text{ DC cable}$









- A2 = $\frac{2 \times 5 m \times 5000W}{0.001 \times 270.2^2 \times 56}$ = 1.2 mm², selected diameter **4 mm² DC cable**
- A3 = $\frac{2 \times 3 \ m \ \times 4900}{0.005 \times 48^2 \times 56}$ = 45.6 mm², selected diameter **50 mm² DC cable**

Double Check Inverter battery terminal size to fit cable size:

Any-Grid model	PSW-H-5KW-	PSW-H-5KW-	PSW-H-3KW-	PSW-H-3KW-			
	230/48V	120/48V	230/24V	120/24V			
Battery cable cross- section	35 ~ 50 mm², AWG 0 ~ AWG 2						



Figure 78: Adama Design

• F2 Fuses from charge controller to Battery

I_{CC}= 80A (max capacity of CC) Add safety margin of 20 %: F2=I_{CC} 1.20 = 80A * 1.20 = 96A **Fuse**_{F2}=100A

ADRA

• F1 Fuses from string to combiner box







I_{SC, Module}=9.56 A F1=I_{SC} String = Isc module F1=I_{SC} String = 9.56A Add safety margin of 20 %: F1=I_{SC} String * 1.20 = 9.56 * 1.20 = 11.47 A **Fuse**_{F1}=15A









Self-Check -	1
--------------	---

Written Test

Instruction: Follow the below selected instruction

The following are true or false items, write true if the statement is true and write false if the statement is false.

N°	Questions and answers
1	A linear increase in current causes a non-linear higher increase in losses
	True or false:
2	PV Fuses are normally rated at 1.4 x the string short circuit current
	True or false:

Answer all the questions listed below. Use the Answer sheet provided in the next page:

N°	Questions and answers
1	Calculate the required cable size for the following:
	 One way cable length of 30m Power of 2000W Acceptable loss of 2% Voltage of 48V Copper cable











Note: the satisfactory rating is as followed

Satisfactory	5 points
Unsatisfactory	Below 4 points

Answer Sheet	Score =
	Rating:
Name	Date









2 Detecting and documenting technical problems

2.1 Introduction

The following paragraph(s) are adapted from (Louie, 2018) chapter 7.

PV systems have many advantages; there is however some considerations to take into account:

- The energy produced by PV arrays is variable and uncertain. PV array power production is driven by sunlight, which varies throughout the day and year.
- Cloud coverage is difficult to forecast, and production might be severely limited during rainy seasons. This adds uncertainty to the design process, leading to arrays that are larger than needed and consequentially more expensive, or smaller than needed causing the system to be unreliable.
- In certain locations, particularly those with perennial cloud coverage or at polar latitudes, the solar resource is inadequate for a PV array to be an economic and practical solution.
- Although PV array prices have fallen globally to much less than US\$0,30/W, energy storage, charge controllers, and other components are needed, increasing the cost and complexity.
- PV arrays have low power density, and so a large amount of roof space or land is needed. For example, a 5 kW system requires approximately 40 m² of surface area for the PV array. Further, the PV array must be tilted and oriented in a specific way to maximize power production. This often necessitates custom made racking structures.

From this it is clear that technical problems should be detected and documented before the system is procured and installed.

2.2 Understanding The Environment

To detect technical problems early, it is imperative to understand the environment where the system to be designed will operate. The environment have many aspects:

- The Location.
 - Access to the site;
 - Weather conditions;
 - Installation environment;
 - Mounting modules;
 - Shading;
 - Appliances to be used (e.g. loads with high startup currents)

ADRA

• Appliance Voltage and consumption;









- Health and safety;
- Security concerns.
- Users.
 - Who will use the system?
 - How will the system be used?
 - What are the exact needs?
 - How to protect users from danger?
 - Affordability
- Regulatory environment
 - Are there specific regulations that need to be adhered to?
- Maintainability.

A good design needs to address all aspects mentioned above. Only by proper understanding of the environment will it be possible to address all the factors.

It is also important to document any concerns and constraints before a system is procured and installed.

2.3 Documenting Technical Problems

There are a number of stages in the development of a PV system in which mistakes can occur:

- Site selection
- Design and planning of the system
 - Selection of components
 - Mechanical failures
 - Electrical failures
- Physical installation of the components
 - Mechanical failures
 - Electrical failures
- Safety (personnel safety as well as safety of installation from e.g. external exposures)
- Service, including inspection & maintenance (insufficient)

This document deals mainly with the design and planning of the system. A good design process will prevent most technical issues. Most technical issues can be avoided if a semi-automated process is designed and followed (as explained in LO5). Apart from following the process, the final design should be peer reviewed where possible. One of the outputs of the design should also include proper instructions to the installers of the system.

The following paragraph(s) are adapted from (Assoc. Prof. Theocharis Tsoutsos, 2011) chapter 4

Most common failures are not encountered because of bad practices in one specific step, but are a combination or accumulation of suboptimal actions in different stages









or simply due to wrong or inadequate communication between the designers and the installers.

The design and planning stages include all decisions taken on the appropriate size of the system as well as the selection of the different components. It is important to take into account basic structural load and wind load calculations. Moreover, emphasis should be put on the sizing, including the size and selection of an appropriate inverter, cables, power optimiser and switch devices as well as combiner boxes and transformers. This task normally ends with a modelling exercise on the future performance of the PV system and therefore also includes knowledge about software and simulation tools for yield modelling.

For residential systems, it is of critical importance to respect the building and safety codes, including measures on ventilation of the building, access for fire departments, maximum load, etc. When the roof is not appropriate for the installation of a PV system, this should be simply acknowledged.

Moreover, the choice of components is critical; especially when it comes to PV systems in sub-optimal locations, such as west-facing roofs or flat roofs where mounting the modules is not an option because of load limitations. Taking into account the latest innovations is critical, e.g. specialised products targeted for east-west facing roofs, light-weight flexible PV modules, etc.

It has to be acknowledged that without sufficient training, the likelihood of mistakes during this step can be significant.

2.3.1 Common Mistakes

Common mistakes to be encountered in this stage are then as listed in Figure 79:

Orientating a system North or West facing (northern hemisphere) may result in a system where the yield is insufficient for the planned consumption. A common mistake is also to disregard the hemisphere where the system is located i.e. facing array south in southern hemisphere and north in northern hemisphere.

Moreover, it is clear that any last minute changes in one of the design stages affects the entire configuration of the PV system design and can have a detrimental impact on the performance or safety of the final installation.











PARAMETER	FAILURE / IMPROPER PRACTICE
1. Site selection	
Orientation	- north / west facing installations
Inclination	 different azimuths or inclinations in the same string array not tilted at an angle of latitude (for throughout the year best performance)
Shading	 place the system in area surrounded by trees and/or buildings seasonal shading is not taken into account
Corrosion	- modules are located in areas exposed to salt water
Biodiversity (for large ground- mounted systems)	- potential impact to wildlife is neglected because of inadequate EIA
2. Design and planning of the sys	tem
Structural load	 age and condition of the roof is not considered not use of specified hardware leading to stability problems no respect to the building codes
Wind load	 inadequate mounting system not mounted on concrete bases
Location	 no respect to the building and safety codes (eg overload the roof, no access for fire departments) BOS are not sited in weather resistant or rain-tight enclosures
Equipment	 inappropriate inverter, undersized cables, power optimiser and switch devices as well as combiner boxes and transformers
Lightning/grounding	 no lightning protection, earthing and surge protection PV system installed in an exposed location allow copper (equipment grounding conductor) to come in contact with the aluminum rails and module frames
Electrical connections	 improper polarity incorrect circuit protection mismatch: e.g. inverter mismatch or generation meter not well fitted to inverter output lengths of electrical wiring are not minimized electrical codes for grid connection not taken into account

Figure 79: Common Mistakes











Written Test

Instruction: Follow the below selected instruction

The following are true or false items, write true if the statement is true and write false if the statement is false.

N°	Questions and answers
1	A common mistake is the wrong orientation of the array
	True or false:
2	One should not worry too much about wind loading when selecting the mounting position of modules
	True or false:
3	Lightning protection is only applicable to large systems
	True or false:

Note: the satisfactory rating is as followed

Satisfactory	3 points
Unsatisfactory	Below 3 points

Answer Sheet	Score =
	Rating:
Name	Date











Information Sheet 3	Completing and reporting the work
---------------------	-----------------------------------

3 Completing and reporting the work

3.1 Introduction

No job is done till the paperwork is finished. It could not be truer for a PV design. Module 8 "Compiling and Producing Solar PV Installation Detailed Report" described this topic in detail. A good design should document every step of the design and should consist of (at least) the following information:

- Project background;
- Client information;
- Site information;
- Design parameters as obtained from the client and site information;
- Technical design of the system including PV Array, Charge Controller(s), Batteries, Inverter, wiring and protection;
- Installation and mounting system;
- Technical constraints and concerns;
- Installation Documents including:
 - Single line diagram;
 - Wiring diagram;
 - Installation manuals of all equipment;
 - Commissioning procedure;
- Bill of material;
- Costing information;

In terms of this Learning Guide (Calculating System Components), the Bill of Materials (BOM) will be considered.

3.2 Bill of Materials

The Bill of Material includes should include the following components:

- PV Generator
 - PV modules;
 - Mounting structure;
- Charge Controller(s)
- Batteries
- Inverter
- Wiring
- Protection devices
- Earthing
- Fixtures and fittings
 - Cable trays and trunking;
 - Conduit;









- Nuts and bolts;
- Cable ties;
- Etc.

Figure 80 shows a sample of a typical BOM.

Component	Size	Description	Numbers/Amount
Solar module	80Wp	Monocrystalline	4
Battery	350Ah	6V Traction	2
Charge controller	30A	PWM with LVD	1
Inverter	250W	Sine wave	1
AC circuit cables	2.5mm ²	Twin flat	30m
DC circuit cables (all sizes and types)	 2.5mm² 4.0mm² 6.0mm² 	Twin flat, multi-strand cable	• 80m • 30m • 20m
Conduit	standard	For exposed cables	30m
Switches	5A	DC rated switches	20
Sockets	240V AC, 5A	Switched	4
Fuses	50A	Main battery fuse DC rated	1
Junction boxes	Standard DC		40
Connector strips	Standard DC	Standard	4 boxes
Earthing		Earth rod	1
Bolts, screws, nuts, etc.		Various boxes	

Figure 80: Bill of Material

The BOM for the Adama Design is shown in Table 14:

Pos.	ltem no.	Description	Quantity	Unit
1	310363	Phaesun PN6M72-350E Modules	14	Pcs
2	340026	Battery OPzS Hoppecke sun power V L 2-730	24	Pcs
3	321728	Inverter / Hybrid Charger Phocos PSW-H-5KW230/48V	1	Pcs
4	161103	Module Support Structure PN-ASS 03	4	
5		Middle Clamp included in 4	16	Pcs
6		End Clamp included in 4	24	Pcs
7	390003	Corrugated Sheet Roof Screw Fitting 160mm	20	bar
8	704230	SOLARFLEX ® - X PV1-F 25mm ²	35	m
9	704232	SOLARFLEX ® - X PV1-F 50mm ²	100	m
10	303588	Cable Solarflex-X 1x 4 black 4mm ²	25	m
11	390900	PV Standard4 Connector 4-6 mm ² Set WM	5	Pcs
13	500090	Connection Box GCB 5-1 200V/50A_gland	1	Pcs
14	108010	Battery Rack Kunstmann	1	Pcs

Table 14: Adama BOM











Pos.	Item no.	Description	Quantity	Unit
		1E.B560.R2		
15		Fuse 100 Amp DC	1	Pcs
18		Fuse 15 Amp DC	4	Pcs

3.3 Design Calculations

The design calculations should also be documented. If a semi-automated spread sheet or customised software is used or, the calculations can be extracted fairly easily in a standard format. Alternatively, a template can be set-up to guide the final report. Figure 81 shows the output of a typical design template – in this case the template used for the Adama design.

	Inverter	Phocus Anygrid PSW-H-5KW-230/48V	1	Р		450 W	
	Cable	SOLAR Cable calculated leangth	4mm2 - 20m				
	Cable	Other Cable	16mm2 - 8m				
	Fuse K1		1	1		250 A	
	Fuse K2		2	1		50 A	
	System Voltage		48 V				
Α	Consumption and electrial Power						
	· · ·						
Δ1	Estimated Consumption of the Costumers						
	Existing Consumers	Power in Watt	Amount	Operation Hours per day	Usage Time	Consumption [Energy]	Total Power in Watt
		[W]	[qty.]	[h/d]		[Wh/d]	[W]
1	Lights	18	20	4	Day/night	1440,00	360,00
2	lights	18	9	12	Day/night	1944,00	162,00
3	Computer	250	3	8	Day/night	6000,00	750,00
4	Printer	700	1	1	Day/night	700,00	700,00
5	Projector	300	1	6	Day/night	1800,00	300,00
6	Internet	15	1	24	Day/night	360,00	15,00
7	Router	15	2	24	Day/night	720,00	30,00
10						0,00	0,00
11						0,00	0,00
Total:						12964,00 Wh/d	2317,00 W
A2	Measured Total Consumption		Actual measured	daily consumpti	ion, when provi	ded	
A3	Energy Consumption [E]	12964,00 Wh/d					
A4	Total Power in Watt [W]	2317,00 W	Relevant for Inve	rter Dimensionir	ng		
A5	Total Power per Day in Watt [W]	2317,00 W	Relevant for Batt	ery Dimensionin	g		
A6	Total Power per Night in Watt [W]	2317.00 W	Relevant for Batt	erv Dimensionin	g		
В	Climate / Insolation	January	February	March	April	May	June
В	Climate / Insolation	January 7,31 kW/m²*d	February 7,61 kWh/m ^{2*} d	March 7,30 kWh/m ^{2*} d	April 6,28 kWh/m ² *d	May 5,83 kWh/m ^{2*} d	June 5,68 kWh/m²*d
В	Climate / Insolation	January 7,31 kW/m²*d July	February 7,61 kWh/m ² *d August	March 7,30 kWh/m ^{2*} d September	April 6,28 kWh/m ^{2*} d October	May 5,83 kWh/m ² *d November	June 5,68 kWh/m²*d December
В	Climate / Insolation	January 7,31 kW/m²*d July 5,35 kW/m²*d	February 7,61 kWh/m ² *d August 5,57 kWh/m ² *d	March 7,30 kWh/m ^{2*} d September 6,15 kWh/m ^{2*} d	April 6,28 kWh/m ^{2*} d October 7,14 kWh/m ^{2*} d	May 5,83 kWh/m²*d November 7,20 kWh/m²*d	June 5,68 kWh/m ^{2*} d December 7,30 kWh/m ^{2*} d
B	Climate / Insolation	January 7,31 kW/m²*d July 5,35 kW/m²*d	February 7,61 kWh/m ² *d August 5,57 kWh/m ² *d	March 7,30 kWh/m ^{2*} d September 6,15 kWh/m ^{2*} d	April 6,28 kWh/m²*d October 7,14 kWh/m²*d	May 5,83 kWh/m ^{2*} d November 7,20 kWh/m ^{2*} d	June 5,68 kWh/m ^{2*} d December 7,30 kWh/m ^{2*} d
B	Climate / Insolation	January 7,31 kW/m ³ *d July 5,35 kW/m ³ *d minimum	February 7,61 kWh/m ^{2*} d August 5,57 kWh/m ^{2*} d average	March 7,30 kWh/m ² *d September 6,15 kWh/m ² *d	April 6,28 kWh/m ^{2*} d October 7,14 kWh/m ^{2*} d	May 5,83 kWh/m ^{2*} d November 7,20 kWh/m ^{2*} d	June 5,68 kWh/m ^{2*} d December 7,30 kWh/m ^{2*} d
B	Climate / Insolation	January 7,31 kW/m [*] d July 5,35 kW/m [*] d minimum 5,35 kW/m ^{2*} d	February 7,61 kWh/m²*d August 5,57 kWh/m²*d average 6,56 kW/m²*d	March 7,30 kWh/m ² *d September 6,15 kWh/m ² *d We will use t	April 6,28 kWh/m ² *d October 7,14 kWh/m ² *d he minimum	May 5,83 kWh/m ^{2*} d November 7,20 kWh/m ² *d value for the mod	June 5,68 kWh/m ² *d December 7,30 kWh/m ² *d
B	Climate / Insolation	January 7,31 kW/m*d July 5,35 kW/m*d minimum 5,35 kW/m2*d	February 7,61 kWh/m2*d August 5,57 kWh/m2*d average 6,56 kW/m2*d	March 7,30 kWh/m²*d September 6,15 kWh/m²*d We will use t	April 6,28 kWh/m²*d October 7,14 kWh/m²*d he minimum	May 5,83 kWh/m ² *d November 7,20 kWh/m ² *d value for the mod	June 5,68 kWh/m ² *d December 7,30 kWh/m ² *d dules
B	Climate / Insolation Insolation minimum / average PV-Generator	January 7,31 kW/m²*d July 5,35 kW/m²*d minimum 5,35 kW/m²*d [P=E/(G*h)]	February 7,61 kWh/m²*d August 5,57 kWh/m²*d average 6,56 kW/m²*d	March 7,30 kWh/m²*d September 6,15 kWh/m²*d We will use t	April 6,28 kWh/m²*d October 7,14 kWh/m²*d he minimum	May 5,83 kWh/m ² *d November 7,20 kWh/m ² *d value for the mod	June 5,68 kWh/m²*d December 7,30 kWh/m²*d dules
B	Climate / Insolation Insolation minimum / average PV-Generator	January 7,31 kW/m²*d July 5,35 kW/m²*d ininimum 5,35 kW/m²*d [P _{Fy} =E/(G*h)]	February 7,61 kWh/m²*d August 5,57 kWh/m²*d average 6,56 kW/m²*d	March 7,30 kWh/m ² *d September 6,15 kWh/m ² *d We will use t	April 6,28 kWh/m²*d October 7,14 kWh/m²*d he minimum P _{PV}	May 5,83 kWh/m ^{2*} d November 7,20 kWh/m ^{2*} d value for the mod Power of the PV Gene Consumption	June 5,68 kWh/m ^{2*} d December 7,30 kWh/m ^{2*} d dules
B B C	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies In1	January 7,31 kW/m ^{2*} d July 5,35 kW/m ^{2*} d 5,35 kW/m ^{2*} d [P _{py} =E/(G*h)] Efficiency	February 7,61 kWh/m ²⁺ d August 5,57 kWh/m ²⁺ d average 6,56 kW/m ²⁺ d	March 7,30 kWh/m ² *d September 6,15 kWh/m ² *d We will use t Project Efficiency	April 6,28 kWh/m²*d October 7,14 kWh/m²*d he minimum P _{PV} E G	May 5,83 kWh/m ² *d November 7,20 kWh/m ² *d value for the mod Power of the PV Gene Consumption Radiation horizonal	June 5,68 kWh/m ^{2*} d December 7,30 kWh/m ^{2*} d dules rator
B B C	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC	January 7,31 kW/m*d July 5,35 kW/m*d 5,35 kW/m2*d [P _{pV} =E/(G*h)] Efficiency hrc	February 7,61 kWh/m ² *d 5,57 kWh/m ² *d average 6,56 kW/m ² *d Range of Efficiency 0,9-0,95	March 7,30 kWh/m ^{2*} d September 6,15 kWh/m ^{2*} d We will use t Project Efficiency 0,95	April 6,28 kWh/m ²⁺ d October 7,14 kWh/m ²⁺ d he minimum P _{PV} E G G h	May 5,83 kWh/m ² *d November 7,20 kWh/m ² *d value for the mod Power of the PV Gene Consumption Radiation horizonal System efficiency FV (i	June 5,68 kWh/m ^{2*} d December 7,30 kWh/m ^{2*} d dules rator 0,6-0,7)
B B C	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator	January 7,31 kW/m*d July 5,35 kW/m*d minimum 5,35 kW/m2*d [P _{PV} =E/(G*h)] Efficiency h _{CC}	February 7,61 kWh/m*d August 5,57 kWh/m*d average 6,56 kW/m**d Range of Efficiency 0,9-0,95 0,97	March 7,30 kWh/m ² *d September 6,15 kWh/m ² *d We will use t Project Efficiency 0,95 0,95	April 6,28 kWh/m ² *d October 7,14 kWh/m ² *d he minimum P _{Py} E G G	May 5,83 kWh/m ²⁺ d November 7,20 kWh/m ²⁺ d value for the mou Power of the PV Gene Consumption Radiation horizonal System efficiency FV (June 5,68 kWh/m ^{2*} d December 7,30 kWh/m ^{2*} d dules rator 0,6-0,7)
B B C	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator Line Losses between Battery and Inverter	January 7,31 kW/m ² d July 5,35 kW/m ² d minimum 5,35 kW/m ² d [P _{PV} =E/(G*h)] Efficiency h _{CC} h _{CC} h _{CC}	February 7,61 kWh/m**d August 5,57 kWh/m**d 6,56 kW/m**d 6,56 kW/m**d 0,9-0,95 0,97 0,97	March 7,30 kWh/m ^{2*} d September 6,15 kWh/m ^{2*} d We will use t Project Efficiency 0,95 0,95	April 6,28 kWh/m ² *d October 7,14 kWh/m ² *d he minimum P _{PV} E G h _{total}	May 5,83 kWh/m ² *d November 7,20 kWh/m ² *d value for the mot Power of the PV Gene Consumption Radiation horizonal System efficiency FV (r	June 5,68 kWh/m ^{2*} d December 7,30 kWh/m ^{2*} d dules rator 0,6-0,7)
B B C	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Une Losses between Battery and Enerator Line Losses between Battery and Inverter Battery Charge and Discharge	January 7,31 kW/m*d July 5,35 kW/m*d 5,35 kW/m*d [P _{py} =E/(G*h)] Efficiency h _{cc} h _{cable bat} P _{bable wentor}	February 7,61 kWh/m ³ *d August 5,57 kWh/m ³ *d 5,56 kW/m ² *d Range of Efficiency 0,9-0,95 0,97 0,8-0,9	March 7,30 kWh/m²*d September 6,15 kWh/m²*d We will use t Project Efficiency 0,95 0,95 0,95 0,95 0,95	April 6,28 kWh/m²+d October 7,14 kWh/m²+d he minimum P _{PV} E G h _{total}	May 5,83 kWh/m ² *d November 7,20 kWh/m ² *d value for the mod Power of the PV Gene Consumption Radiation horizonal System efficiency FV (i	June 5,68 kWh/m ^{2*} d December 7,30 kWh/m ^{2*} d dules rator 0,6-0,7)
B C C1	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator Line Losses between Battery and Inverter Battery Charge and Discharge Fificiery of the Charge Controller	January 7,31 kW/m*d July 5,35 kW/m*d minimum 5,35 kW/m2*d [P _{PV} =E/(G*h)] Efficiency h _{CC} h _{Cable-bat} h _{Cable-bat} h _{cable-internor} h _{bat}	February 7,51 kWh/m*d August 5,57 kWh/m*d average 6,56 kW/m*ed 6,56 kW/m*ed 6,56 kW/m*ed 0,90,95 0,97 0,97 0,97 0,97 0,97 0,90,98	March 7,30 kWh/m²*d September 6,15 kWh/m²*d We will use t Project Efficiency 0,95 0,95 0,95 0,95 0,95 0,95	April 6,28 kWh/m ² *d October 7,14 kWh/m ² *d he minimum P _{PV} E G h _{total}	May 5,83 kWh/m ² *d November 7,20 kWh/m ² *d value for the mou Power of the PV Gene Consumption Radiation horizonal System efficiency FV (r	June 5,68 kWh/m ^{2*} d December 7,30 kWh/m ^{2*} d dules rator 0,6-0,7)
B B C	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator Line Losses between Battery and Inverter Battery Charge and Discharge Efficiency of the Charge Controller Efficiency of the Lineareter	January 7,31 kW/m ² d July 5,35 kW/m ² d minimum 5,35 kW/m ² d [P _{py} =E/(G*h)] Efficiency h _{ctc} h _{cabk-bat} h _{cabk-bat} h _{tat} h _{tat}	February 7,61 kWh/m**d August 5,57 kWh/m**d 6,56 kW/m**d 6,56 kW/m**d 0,9-0,95 0,97 0,8-0,9 0,9-0,98	March 7,30 kWh/m²*d September 6,15 kWh/m²*d We will use t Project Efficiency 0,95 0,95 0,95 0,95 0,95	April 6,28 kWh/m²*d October 7,14 kWh/m²*d he minimum P _{Py} E G h _{total}	May 5,83 kWh/m ² *d November 7,20 kWh/m ² *d value for the mot Power of the PV Gene Consumption Radiation horizonal System efficiency FV (r	June 5,68 kWh/m²*d December 7,30 kWh/m²*d dules rator 0,6-0,7)
B B C	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator Line Losses between Battery and Inverter Battery Charge and Discharge Efficiency of the Charge Controller Efficiency of the Inverter Influence of the Ambient Lemenative	January 7,31 kW/m³*d July 5,35 kW/m³*d 5,35 kW/m²*d (P _{py} =E/(G*h)) Efficiency h _{CC} h _{Cable bat} h _{Cable bat} h _{CC} h _{Cable} h _{CC} h _{CC}	February 7,51 kWh/m ³⁺ d August 5,57 kWh/m ³⁺ d 5,56 kW/m ²⁺ d 6,56 kW/m ²⁺ d 8,50 kW/m ²⁺ d 9,90,95 0,97 0,97 0,97 0,97 0,97 0,90,98 0,97 0,90,98 0,90,98 0,90,98	March 7,30 kWh/m²*d September 6,15 kWh/m²*d We will use t Project Efficiency 0,95 0,95 0,95 0,95 0,95 0,95 0,95	April 6.28 kWh/m ² *d October 7,14 kWh/m ² *d he minimum P _{PV} E G h _{total}	May 5,83 kWh/m ² #d November 7,20 kWh/m ² #d value for the mod Power of the PV Gene Consumption Radiation horizonal System efficiency FV (June 5,68 kWh/m ^{2*} d December 7,30 kWh/m ^{2*} d dules rator 0,6-0,7)
B B C	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator Line Losses between Battery and Inverter Battery Charge and Discharge Efficiency of the Inverter Influence of the Inverter Influence of the Ambient Temperature Insolation	January 7,31 kW/m*d July 5,35 kW/m*d 5,35 kW/m*d (P _{PV} =E/(G*h)) Efficiency h _{CC} h _{cabe-bat} h _{cabe-bat} h _{cc} h _{mv} h _{mv} h _{mv}	February 7,61 kWh/m³*d August 5,57 kWh/m³*d average 6,56 kW/m³*d Range of Efficiency 0,9-0,95 0,97 0,9-0,95 0,97 0,9-0,95 0,9-0,95 0,9-0,95	March 7,30 kWh/m²*d September 6,15 kWh/m²*d We will use t Project Efficiency 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95	April 6,28 kWh/m²*d October 7,14 kWh/m²*d he minimum P _{PV} E G h _{total}	May 5,83 kWh/m ² *d November 7,20 kWh/m ² *d value for the mou Power of the PV Gene Consumption Radiation horizonal System efficiency FV (r	June 5,68 kWh/m ^{2*} d December 7,30 kWh/m ^{2*} d dules rator 0,6-0,7)
B B C	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator Line Losses between Battery and Inverter Battery Charge and Discharge Efficiency of the Charge Controller Efficiency of the Inverter Influence of the Ambient Temperature Insolation	January 7,31 kW/m ² d July 5,35 kW/m ² *d minimum 5,35 kW/m ² *d (P _{PV} =E/(G*h)) Efficiency h _{cbk} h _{cbk} h _{cbk} h _{cbk} h _{bbt} h _{bbt} h _{cb}	February 7,61 kWh/m**d August 5,57 kWh/m**d 6,56 kW/m**d 6,56 kW/m**d 7,56 kW/m**d 0,90,95 0,97 0,8-0,9 0,9-0,98 0,8-0,9 0,9-0,98 0,9-0,95 0,9-0,95 0,9-1,1	March 7,30 kWh/m ²⁺ d September 6,15 kWh/m ²⁺ d We will use t Project Efficiency 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95	April 6,28 kWh/m²*d October 7,14 kWh/m²*d he minimum P _{Py} E G h _{total}	May 5,83 kWh/m ² *d November 7,20 kWh/m ² *d value for the mot Power of the PV Gene Consumption Radiation horizonal System efficiency FV (r	June 5,68 kWh/m²*d December 7,30 kWh/m²*d dules rator 0,6-0,7)
B	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator Line Losses between Battery and Inverter Battery Charge and Discharge Efficiency of the Charge Controller Efficiency of the Inverter Influence of the Ambient Temperature Insolation	January 7,31 kW/m²d July 5,35 kW/m²*d 5,35 kW/m²*d (P _{py} =E/(G*h)) Efficiency h _{CC} h _{Cdk} h _{Cd} h _{Cd} h _{Cd} h _m Calculated as product of all efficiencies	February 7,61 kWh/m**d August 5,57 kWh/m**d 6,56 kW/m**d 6,56 kW/m**d 0,9-0,95 0,97 0,9-0,95 0,97 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95	March 7,30 kwh/m²*d September 6,15 kwh/m²*d We will use t Project Efficiency 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,095 1,00 Typical Efficiency	April 6.28 kWh/m ²⁺ d October 7,14 kWh/m ²⁺ d he minimum P _{PV} E G h _{total}	May 5,83 kWh/m ² #d November 7,20 kWh/m ² #d value for the mod Power of the PV Gene Consumption Radiation horizonal System efficiency FV (i	June 5,68 kWh/m ^{2*} d December 7,30 kWh/m ^{2*} d dules rator 0,6-0,7)
B C C1 C2	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator Line Losses between Battery and Inverter Battery Charge and Discharge Efficiency of the Inverter Influence of the Ambient Temperature Insolation System Efficiency [h] selected	January 7,31 kW/m*d July 5,35 kW/m*d minimum 5,35 kW/m2*d [P _{py} =E/(G*h)] Efficiency h _{cc} h _{cbit} h _{cc} h _{bd} h _{cc} h _{bd} Calculated as product of all efficiencies 0,66	February 7,61 kWh/m*d 3,57 kWh/m*d 3,57 kWh/m*d 6,56 kW/m*e 8,56 kW/m*e 8,56 kW/m*e 0,9-0,95 0,97 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95	March 7,30 kWh/m²*d September 6,15 kWh/m²*d We will use t Project Efficiency 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,90 0,95 1,00 Typical Efficiency 0,65	April 6.28 kWh/m ² *d October 7,14 kWh/m ² *d he minimum P _{PV} E G G h _{total}	May 5,83 kWh/m ² *d November 7,20 kWh/m ² *d value for the mod Power of the PV Gene Consumption Radiation horizonal System efficiency FV (i the 0,65	June 5,68 kWh/m ^{2*} d December 7,30 kWh/m ^{2*} d dules rator 0,6-0,7)
В В С С С С С С	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator Line Losses between Battery and Inverter Battery Charge and Discharge Efficiency of the Charge Controller Efficiency of the Inverter Influence of the Ambient Temperature Insolation System Efficiency [h] selected	January 7,31 kW/m ² *d July 5,35 kW/m ² *d minimum 5,35 kW/m ² *d [P _{PV} =E/(G*h]] Efficiency h _{cabe-bat} h _{cabe-bat} h _{cabe-bast} h _{cabe-bast} h _{bat} h _{bat} h _{bat} h _{bat} h _{cabe} h _{cabe} h _{bat} h _{cab} h _{cabe} h _{cab} h _{cab}	February 7,61 kWh/m ³⁺ d August 5,57 kWh/m ³⁺ d average 6,56 kW/m ²⁺ d Range of Efficiency 0,9-0,95 0,97 0,8-0,9 0,9-0,98 0,85-0,95 0,9-0,95 0,9-1,1	March 7,30 kWh/m²*d September 6,15 kWh/m²*d We will use t Project Efficiency 0,95 0,06	April 6.28 kWh/m²td October 7,14 kWh/m²td he minimum P _{Py} E G G h _{total}	May 5,83 kWh/m ² *d 7,20 kWh/m ² *d value for the mor Power of the PV Gene Consumption Radiation horizonal System efficiency FV (r	June 5,68 kWh/m²*d December 7,30 kWh/m²*d dules rator 0,6-0,7)
B C C1 C2 C2 C3	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator Line Losses between Battery and Inverter Battery Charge and Discharge Efficiency of the Charge Controller Efficiency of the Inverter Influence of the Ambient Temperature Insolation System Efficiency [h] selected PV-Generator [P _{PV} =E/(G*h)]	January 7,31 kW/m ² *d July 5,35 kW/m ² *d 5,35 kW/m ² *d (P _{PV} =E/(G*h)) Efficiency h _{cdb} =bat h _{cdb} =bat h _{bdf} h _{bd} h _{bd} h _{cc} h _{bd} h _{bd} h _{cc} h _{bd} h _{cd} h _{cd} N _c N _c N _{cd} h _{cd} N _{cd}	February 7,61 kWh/m ³⁺ d August 5,57 kWh/m ³⁺ d average 6,56 kW/m ²⁺ d Range of Efficiency 0,9-0,95 0,97 0,8-0,9 0,9-0,98 0,85-0,95 0,9-0,91	March 7,30 kWh/m²*d September 6,15 kWh/m²*d We will use t Project Efficiency 0,95 0,65 Calculation	April 6.28 kWh/m²td October 7,14 kWh/m²td he minimum P _{Pv} E G G h _{total}	May 5,83 kWh/m ^{2*} d November 7,20 kWh/m ^{2*} d value for the mod Power of the PV Gene Consumption Radiation horizonal System efficiency FV (r the 0,65 ninimum radiation	June 5,68 kWh/m²*d December 7,30 kWh/m²*d dules rator 0,6-0,7)
B B C C1 C2 C2 C3	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator Line Losses between Battery and Inverter Battery Charge and Discharge Efficiency of the Charge Controller Efficiency of the Inverter Influence of the Ambient Temperature Insolation System Efficiency [h] selected PV-Generator [P _{PV} =E/(G*h)]	January 7,31 kV/m ² d July 5,35 kW/m ² *d minimum 5,35 kW/m ² *d [P _{PV} =E/(G*h)] Efficiency h _{cc} h _{cabe-bat} h _{cabe-bat} h _{cabe} h _{cc} h _{bat} h _{cc} h _{cab} h _{cc} h _{cab} h _{cc} h _{cab} h _{cc} h _{cab} h _{cc} h _{cab} h _{cc} h _{cc} h _{cab} h _{cc} h _{cc} h _{cab} h _{cc} h _{cab} h _{cc} h _{cab} h _{cc} h _{cab} h _{cc} h _{cb} h _{cc} h _{cb} h _{cb} S727,97 Wp	February 7,61 kWh/m**d August 5,57 kWh/m**d 6,56 kW/m**d 6,56 kW/m**d 0,940,95 0,97 0,97 0,97 0,97 0,97 0,9-0,98 0,8-0,99 0,9-0,95 0,9-0,95 0,9-0,11	March 7,30 kwh/m²*d September 6,15 kwh/m²*d We will use t Project Efficiency 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95 1,00 Typical Efficiency 0,65 Calculation	April 6.28 kWh/m²*d October 7.14 kWh/m²*d he minimum P _{Pv} E G h _{total} We will use based on r	May 5,83 kWh/m ² *d November 7,20 kWh/m ² *d value for the mod Power of the PV Gene Consumption Radiation horizonal System efficiency FV (r the 0,65 ninimum radiat	June 5,68 kWh/m ^{2*} d December 7,30 kWh/m ^{2*} d dules rator 0,6-0,7) tion!
B C C1 C2 C2 C3 C4	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator Line Losses between Battery and Inverter Battery Charge and Discharge Efficiency of the Charge Controller Efficiency of the Inverter Influence of the Ambient Temperature Insolation System Efficiency [h] selected PV-Generator [P _{PV} =E/(G*h)] Number of Modules	January 7,31 kV/m²d July 5,35 kV/m²*d 5,35 kV/m²*d (P _{py} =E/(G*h)) Efficiency h _{CC} h _{Cable bat} h _{Cable bat} h _{Cable bat} h _{CC} h _{Cable bat} h _{CC} h _{Cable bat} Calculated as product of all efficiencies 0,66	February 7,51 kWh/m ³⁺ d August 5,57 kWh/m ³⁺ d 5,55 kW/m ²⁺ d 6,56 kW/m ²⁺ d 6,56 kW/m ²⁺ d 0,9-0,95 0,97 0,97 0,97 0,97 0,9-0,98 0,85-0,95 0,9-0,95 0,9-0,95	March 7,30 kwh/m²*d September 6,15 kwh/m²*d We will use t Project Efficiency 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95	April 6.28 kWh/m ^{2*} d October 7,14 kWh/m ^{2*} d he minimum P _{PV} E G G h _{total} / / We will use based on r	May 5,83 kWh/m ² #d November 7,20 kWh/m ² #d value for the mod Power of the PV Gene Consumption Radiation horizonal System efficiency FV (I System efficiency FV (I the 0,65 ninimum radiat	June 5,68 kWh/m ^{2*d} December 7,30 kWh/m ^{2*d} dules rator 0,6-0,7) tion!
B C C1 C2 C3 C4	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator Line Losses between Battery and Inverter Battery Charge and Discharge Efficiency of the Charge Controller Efficiency of the Inverter Influence of the Ambient Temperature Insolation System Efficiency [h] selected PV-Generator [P _{PV} =E/(G*h)] Number of Modules Selected Type of Modules	January 7,31 kW/m ² *d July 5,35 kW/m ² *d minimum 5,35 kW/m ² *d [P _{PV} =E/(G*h]] Efficiency h _{cdb} - h _{cdb} - h _{cdb} - h _{cd} - h _{bdt} - h _{cd} - h _{bd} - h _{cd} - D _c -	February 7,61 kWh/m ³⁺ d August 5,57 kWh/m ³⁺ d average 6,56 kW/m ²⁺ d Range of Efficiency 0,9-0,95 0,97 0,8-0,9 0,9-0,98 0,85-0,95 0,9-0,95 0,9-0,91	March 7,30 kWh/m²*d September 6,15 kWh/m²*d We will use t Project Efficiency 0,95 0,65 Calculation	April 6.28 kWh/m²td October 7,14 kWh/m²td he minimum P _{Pv} E G G h _{total} / / / / / / / / / / / / / / / / / / /	May 5,83 kWh/m ^{2*} d November 7,20 kWh/m ^{2*} d value for the mod Power of the PV Gene Consumption Radiation horizonal System efficiency FV (r the 0,65 ninimum radiat	June 5,68 kWh/m ^{2*} d December 7,30 kWh/m ^{2*} d dules rator 0,6-0,7)
B C C1 C2 C3 C4	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator Line Losses between Battery and Inverter Battery Charge and Discharge Efficiency of the Charge Controller Efficiency of the Inverter Influence of the Ambient Temperature Insolation System Efficiency [h] selected PV-Generator [P _{PV} =E/(G*h)] Number of Modules Selected Type of Modules Module Power Pnom	January 7,31 kV/m²d July 5,35 kW/m²*d minimum 5,35 kW/m²*d [P _{PV} =E/(G*h)] Efficiency h _{CC} h _{Cd} h _{Cd} h _{Cd} h _{Cd} h _m h _{Cd} 3727,97 Wp	February 7,61 kWh/m**d August 5,57 kWh/m**d 6,56 kW/m**d 6,56 kW/m**d 0,940,95 0,97 0,97 0,97 0,8-0,9 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95	March 7,30 kWh/m²*d September 6,15 kWh/m²*d We will use t Project Efficiency 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95	April 6.28 kWh/m²*d October 7.14 kWh/m²*d he minimum P _{Pv} E G h _{total} We will use based on r	May 5,83 kWh/m ² *d November 7,20 kWh/m ² *d value for the mod Power of the PV Gene Consumption Radiation horizonal System efficiency FV (r the 0,65 ninimum radiat	June 5,68 kWh/m ^{2*d} December 7,30 kWh/m ^{2*d} dules fator 0,6-0,7) tion!
B C C1 C2 C3 C4	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator Line Losses between Battery and Inverter Battery Charge and Discharge Efficiency of the Inverter Influence of the Ambient Temperature Insolation System Efficiency [h] selected PV-Generator [P _{PV} =E/(G*h)] Number of Modules Selected Type of Modules Selected Type of Modules Needed Number of the Modules, P _{PV} /P _{mem}	January 7,31 kV/m²d July 5,35 kV/m²d minimum 5,35 kV/m²d (P _{py} =E/(G*h)) Efficiency h _{CC} h _C h _{CC} h _{CC} h _C h _{CC} h _C h _C	February 7,61 kWh/m**d August 5,57 kWh/m**d 6,56 kW/m**d 8,56 kW/m**d 9,90,95 0,97 0,97 0,97 0,97 0,97 0,97 0,97 0,90,98 0,95 0,90,95 0,90,95 0,9-0,95	March 7,30 kWh/m²*d September 6,15 kWh/m²*d We will use t Project Efficiency 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95	April 6.28 kWh/m ^{2*} d October 7,14 kWh/m ^{2*} d he minimum P _{PV} E G G h _{total} / / / / / / / / / / / / / / / / / / /	May 5,83 kWh/m ²⁺ d November 7,20 kWh/m ²⁺ d value for the mod Power of the PV Gene Consumption Radiation horizonal System efficiency FV (I the 0,65 ninimum radiat	June 5,68 kWh/m ^{2*d} December 7,30 kWh/m ^{2*d} dules dules 0,6-0,7) tion!
B C C1 C2 C2 C3 C4	Climate / Insolation Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Une Losses between Battery and Generator Line Losses between Battery and Inverter Battery Charge and Discharge Efficiency of the Inverter Efficiency of the Inverter Infiluence of the Ambient Temperature Insolation System Efficiency [h] selected PV-Generator [P _{PV} =E/(G*h)] Number of Modules Selected Type of Modules Module Power Pnom Needed Number of the Modules, P _{EV} /P _{num}	January 7,31 kW/m ³⁺ d July 5,35 kW/m ³⁺ d minimum 5,35 kW/m ²⁺ d [P _{PV} =E/(G*h]] Efficiency h _{CC} h _{CC} h _{CC} h _{Date-bast} h _{bat} h _{CC} h _m h _{bat} Calculated as product of all efficiencies 0,66 3727,97 Wp Phaesun PN6M72-350 E 350,00 Wp 10,65	February 7,61 kWh/m*d August 5,57 kWh/m*d 6,56 kW/m*e Range of Efficiency 0,9-0,95 0,97 0,8-0,95 0,97 0,8-0,95 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95	March 7,30 kWh/m ^{2*} d September 6,15 kWh/m ^{2*} d We will use t Project Efficiency 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95	April 6.28 kWh/m ^{2*} d October 7,14 kWh/m ^{2*} d he minimum P _{PV} E G G h _{total}	May 5,83 kWh/m ² *d November 7,20 kWh/m ² *d value for the more Power of the PV Gene Consumption Radiation horizonal System efficiency FV (i the 0,65 ninimum radiat	June 5,68 kWh/m ^{2*d} December 7,30 kWh/m ^{2*d} dules rator 0,6-0,7) tion!
B C C1 C2 C3 C4	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Une Losses between Battery and Generator Une Losses between Battery and Inverter Battery Charge and Discharge Efficiency of the Charge Controller Efficiency of the Inverter Influence of the Ambient Temperature Insolation System Efficiency [h] selected PV-Generator [P _{FV} =E/(G*h)] Number of Modules Selected Type of Modules Module Power Pnom Needed Number of the Modules, P _{FV} /P _{nom} Selected Number of Modules	January 7,31 kW/m ² d July 5,35 kW/m ² *d minimum 5,35 kW/m ² *d (P _{PV} =E/(G*h)) Efficiency h _{CC} h _{CC} h _{Cdb-bast} h _{Cdb} h _{Cd} h _{Cdb} h _{Cd} h _{Cdb} h	February 7,61 kWh/m ³⁺ d August 5,57 kWh/m ³⁺ d 6,56 kW/m ²⁺ d 6,56 kW/m ²⁺ d 0,9-0,95 0,97 0,9-0,98 0,8-0,9 0,9-0,98 0,8-0,9 0,9-0,95 0,9-0,95 0,9-0,95 0,9-1,1	March 7,30 kWh/m ² *d September 6,15 kWh/m ² *d We will use t Project Efficiency 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95	April 6.28 kWh/m²*d October 7.14 kWh/m²*d he minimum P _{Py} E G h _{total} We will use based on r	May 5,83 kWh/m ² *d 7,20 kWh/m ² *d value for the mor Power of the PV Gene Consumption Radiation horizonal System efficiency FV (r the 0,65	June 5,68 kWh/m ^{2*d} December 7,30 kWh/m ^{2*d} dules rator 0,6-0,7) tion!
B B C C1 C2 C3 C3 C4 C4 C4	Climate / Insolation Insolation minimum / average PV-Generator Efficiencies [h] Deviation MPP / Type of the CC Line Losses between Battery and Generator Line Losses between Battery and Inverter Battery Charge and Discharge Efficiency of the Charge Controller Efficiency of the Inverter Influence of the Ambient Temperature Insolation System Efficiency [h] selected PV-Generator [P _{PV} =E/(G*h)] Number of Modules Selected Type of the Modules, P _{Fv} /P _{ream} Selected Number of Modules Power of the PV-Generators	January 7,31 kV/m²d July 5,35 kW/m²*d minimum 5,35 kW/m²*d [P _{py} =E/(G*h)] Efficiency h _{cc} h _{cd} h _{cd} 14 4 4900,00 Wp	February 7,61 kWh/m**d August 5,57 kWh/m**d 6,55 kW/m**d 6,55 kW/m**d 0,9-0,95 0,97 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95 0,9-0,95	March 7,30 kWh/m²*d September 6,15 kWh/m²*d We will use t Project Efficiency 0,95 0,95 0,95 0,95 0,95 0,95 0,95 0,95	April 6.28 kWh/m²*d October 7.14 kWh/m²*d he minimum P _{Pv} E G G h _{total} We will use based on r	May 5,83 kWh/m ² *d November 7,20 kWh/m ² *d value for the mod Power of the PV Gene Consumption Radiation horizonal System efficiency FV (r the 0,65 ninimum radiat	June 5,68 kWh/m ^{2*d} December 7,30 kWh/m ^{2*d} dules rator 0,6-0,7) tion!











D	System Voltage	48 V
F	Battery Dimensioning	
-		
	Consumption [E]	12964 Wh/d
	Autonomous Days [A]	1,00 d
	Voltage of the Battery-Bank [V]	48 V
	max. Depth of Discharge of the Battery in %	50,00%
E1	Required Electrical Capacity [C10]	540,17 Ah
	Required Electrical Capacity [C100]	675,21 Ah
a	Voltage of the selected Batteries [V]	2 V
b	Capacity of the selected Batteries [Ah] C10	686 Ah
C b	Voltage of the required Battery-Bank [V]	48 V
a	Number of Batteries parallel connected	0.79
f	Number of Batteries	18 90
		10,50
E2	Selected Batteries	
	Selected Type of Batteries	Hoppecke sun power VL7-730
с	Voltage of the Battery-Bank [V]	48 V
a	Voltage of the selected Batteries [V]	2 V
g	Number of Batteries series-connected	24
h	Number of Batteries parallel-connected	1
i	Capacity of the selected Batteries [Ah] C10	546 Ah
j	Number of Batteries	24,00
	Total Capacity C10 actual	546,000 Ah
	Total Capacity C10 desired	540,17 Ah
	actual C10 >C10 desired	ok
F	Configuration of the Modules	
F1	U, I and α of the Modules (s. Datasheet)	
	Selected Type of Modules	Phaesun PN6M72-350 E
k	V _{oc}	47,20 V
1	V _{MPP}	38,60 V
m	I _{SC}	9,56 A
n	I _{MPP}	9,08 A
0	α _{voc}	-0,30 %/K
р	α _{VMPP}	-0,30 %/K
q	α _{ISC}	0,040 %/K
r	α _{IMPP}	0,040 %/K
F2	Ivioquie installation	
		14
rr	Number of Strings	2
S	Number of Modules per String	7











	Charge Controller Dimensioning	
	Charge Controller Type	Phocus Anygrid PSW-H-5KW-230/48V
	Nominal Power Rating	5000 W
	V System	48 V
	System Voltage	
	Voc max	450 V
	MAX Open-Circuit Voltage Modules	
	(at minimum Temperature)	120.1
	VOC MIN	120 V
	(at minimum Tomporature)	
		120.1/
	Input	120 V
	Vmpp max	430 V
	Input	-30 1
	max. Current Modules	26 A
	max, Current Charge Controller (permanent)	26 A
	max. Current Charge Controller (peak load)	26 A
	Number of Charge Controllers	1
	Number of Modules each Subsystem	14
	,,,,,,,,,_	
2	Power Check	
	Power of the PV-Generators	4900 W/n
	Nominal Power Rating	4900 Wp
		0.00
	Dette shock	0,98
	Katio check	OK
	In other words, the PV generator power can be upt	
	to 20% bigger thant the nominal power of the CC.	
i1	Ambient Temperature	
	Minimum Temperature Modules	5,00 °C
	Maximum Temperature Modules	85,00 °C
	Insolation, if it's sharply higher as according to STC	1000 W/m²*d
i2	Maximum System Voltage, Voc at Tmin	
	Voc Module at STC (25°)	47,20 V
	$V_{\alpha} = T_{\alpha} = \alpha + \frac{1}{2} \sum_{\alpha} \frac{1}{2} $	2.83 V
	Number of Modules per String	7
		/
	V _{oc} String at STC (25°)	330,40 V
	V_{OC} at $T_{min} = \alpha_{VOC} x (T_{min} - 25^{\circ}) x V_{OC,String}$	19,82 V
	V _{OC. Tmin} each String (T _{min})	350,22 V
	Voc max (at minimum Temperature)	450.00 V
		ak
	IS V _{OC, Tmin, String} <maxv<sub>OC, CC</maxv<sub>	ОК
	Voc min (at minimum Temperature)	120,00 V
	Is V _{OC. Tmin. String} >minV _{OC. CC}	ok
	Minimum System Voltage, Vmnn at Tmax	
	V	270.20 V
		270,20 V
	v_{MPP} at $I_{min} = \alpha_{MPP} X (I_{min} - 25^{\circ}) X V_{MPP, String}$	-48,64 V
	V _{MPP} , _{Tmin} for String (Tmin)	221,56 V
	V _{min} Charge Controller	120,00 V
	actual V <	ok
	MPP, Tmax MinCC	UN UN
	Manimum Gratam Grant In	
13	iviaximum System Current, Impp at Tmax	
	I _{MPP} Module at STC (25°)	9,08 A
	I_{MPP} at $T_{max} = \alpha_{MPP} x (T_{max} - 25^{\circ}) x I_{MPP}$	0,22 A
	Amount of strings in parallel	2
	I _{MPP} System at STC (25°)	18,16 A
	$I_{\text{MDD}} \text{ at } T_{\text{max}} = \alpha_{\text{MDD}} x (T_{\text{max}} - 25^{\circ}) x I_{\text{MDD}} c_{\text{max}}$	0.44 A
)	Luco T of the System (T)	18 60 A
-	mpp, max of the system (Tmax)	10,00 //
	I _{MPP} , T _{max} of the System (T _{max}) and G _{max}	18,60 A
	Imay Charge Controller	26,00 A
		ok
		UK
	Actual I _{MPP, Tmax} <i<sub>maxCC</i<sub>	EDBOPIAN AND AND AND
1		
-	ACTUAL I MAPP, Tmax<1 maxCC	

н	Inverter								
	Power by Night P _{Inv} = 1,3 x P _{PV}	3012 W							
	Power by Day P _{inv} = 1,3 x P _{PV}	3012 W							
	maximum Power (Sum of all Consumers)	2317 W							
	Selected Inverter	Phocus Anygrid PSW-H-5KW-230/48V							
	Power Inverter (continuous)	5000 W							
-	Power Inverter (30s)	5000 W	1						
	Power Inverter (5c)	10000 W	-						
	Number of Inventors	10000 W	1						
	Number of Inverters	1							
	Total Power of all Inverters (continuous)	5000 W	_						
	Total Power Inverters (30min)	5000 W							
	Total Power of all Inverters (5s)	10000 W							
1	Check of the min. Battery capacity								
	Minimum Capacitiy of the Batteries	Cmin= PINV _{4Cmm} / U x 5h							
	P., Inverter power: Pac. nom. [W]	5000 W							
-	System Voltage (V)	49.1/	-						
	C Constitute of the Potterion	521 Ab	-						
	C _{min} capacity of the Batteries								
	bo the selected batteries lit?	ОК							
_									
1	Kabel	L	LF	Pmax	к	V	Required Cable	Selected Cable	Selected Cable
		Single Distance	Loss Factor	Affiliated Power	Con-ductivity	Voltage	Diameter	Diameter	Diameter
							A=LxP/(LF*V ² xK)		
	A1 Single Cable Length between Modules and Terminal	10 m	3,00%	2450 W	56	270,20 V	0,4 mm ²	4,0 mm²	20 m
-	Box (PPV)								
	A2 Single Cable Length between Charge Controller and	2,00 m	3,00%	10000 W	56	48,00 V	10,3 mm²	16,0 mm²	4 m
	Battery (PPV)	2.00 m	2.00%	10000.11/	56	40.1/	40.2	46.0	4.00
	A3 Single Cable Length between Battery and Inverter	2,00 m	3,00%	10000 W	56	48 V	10,3 mm*	16,0 mm ⁻	4 m
	(P _{max} Inv 30min.)								
	Material of the Cables	Cu							
	Comments:	Current Stability with free Installation just 130 A		-					
		$K_{Cu} = 56 \text{ m} / \Omega \cdot \text{mm}^2$	$K_{\rm M} = 34 \text{ m} / \Omega \cdot \text{mm}$	1 ²					
			A - 7						
		-							
	Selected Cable selected diameter	25,0 mm²							
	Selected Cable selected diameter SOLAR Cable calculated leangth	25,0 mm² 4mm2 - 20m	4,0 mm ²						
	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable	25,0 mm² 4mm2 - 20m 16mm2 - 8m	4,0 mm ²		A1 (P _{PV})				
	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable	25,0 mm² 4mm2 - 20m 16mm2 - 8m	4,0 mm ²		A1 (P _{PV})				
ĸ	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses	25,0 mm² 4mm2 - 20m 16mm2 - 8m	4,0 mm ²		A1 (P _{PV})		=/-		
K K1	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses	25,0 mm ⁴ 4mm2 - 20m 16mm2 - 8m	4,0 mm ²		A1 (P _{PV})				
K K1	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses KL Fuse from Inverter / MPPT to Battery Peax	25,0 mm ¹ 4mm2 - 20m 16mm2 - 8m	4,0 mm ²		A1 (P _{PV})	A3 (P _{max,INV})			
K K1	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses KI Fuse from Inverter / MPPT to Battery Pmax (5 see pask lead)	25,0 mm² 4mm2 - 20m 16mm2 - 8m 10000 W	4,0 mm ²		A1 (P _{PV})	A3 (P _{max,RV})	~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~~		
K K1	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses KL Fuse from Inverter / MPPT to Battery Pmax (5 see peak load) Imax = Pmax/Usystem	25,0 mm ¹ 4mm2 - 20m 16mm2 - 8m 10000 W 208 A	4,0 mm ²		A1 (P _{Pv})	A3 (P _{max,NV})	~		
<u>к</u> к1	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses K1 Fuse from Inverter / MPPT to Battery Pmax (5 sec peak load) Imax = Pmax/Lsystem	25,0 mm ³ 4mm2 - 20m 16mm2 - 8m 10000 W 208 A	4,0 mm ²		A1 (P _{PV})	A3 (P _{max,NV})			
K K1	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses K1 Fuse from inverter / MPPT to Battery Pmax (5 see peak load) imax = Pmax/Usystem Add safety margin of 20%	25,0 mm ⁴ 4mm2 - 20m 16mm2 - 8m 10000 W 208 A 250 A 250 A	4,0 mm ² 16,0 mm ²		A1 (P _{PV})	A3 (P _{max,Inv})	=/~		
K K1	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses K1 Fuses from Inverter / MPPT to Battery Pmax (5 sec peak load) (5 sec pea	25,0 mm ³ 4mm2 - 20m 16mm2 - 8m 10000 W 208 A 208 A 250 A 250 A	4,0 mm ² 16,0 mm ²		A1 (P _{PV})	A3 (P _{max,inv})	=		
K K1	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses KI Fuse from Inverter / MPPT to Battery Pmax (5 sec peak load) imax = Pmax/Usystem Add safety margin of 20% KI Fuse selected	25,0 mm ⁴ 4mm2 - 20m 16mm2 - 8m 10000 W 208 A 250 A 250 A	4,0 mm ² 16,0 mm ²		A1 (P _{PV})	A3 (P _{max,IIV})	=/~		
K K1	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses K1 Fuse from Inverter / MPPT to Battery Pmax (Ssee peak load) Imax = Pmax/Usystem Add safety magin of 20% K1 Fuse selected K2 Fuses from charge control to Battery	25,0 mm ¹ 4mm2 - 20m 16mm2 - 8m 10000 W 208 A 208 A 250 A	4,0 mm ² 16,0 mm ²		A1 (P _{pv})	A3 (P _{max,mv})	consumer		
<u>к</u> к1	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses K1 Fuse from Inverter / MPPT to Battery Pmax (5 sec peak load) Immax = Pmax(Juystem Add safety margin of 20% K1 Fuse selected K2 Fuses from charge control to Battery kc	25,0 mm ⁴ 4mm2 - 20m 16mm2 - 8m 10000 W 208 A 250 A 250 A 250 A	4,0 mm ² 16,0 mm ²		A1 (P _{PV})	A3 (P _{max,PNV})	consumer		
<u>к</u> к1	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses KI Fuse from Inverter / MPPT to Battery Pmax (5 see peak load) Imax = Pmax/Uxystem Ad safety margin of 20% KI Fuse selected K2 Fuses from charge control to Battery kc Add safety margin of 20%	25,0 mm ¹ 4mm2 - 20m 16mm2 - 8m 10000 W 208 A 250 A 250 A 250 A 250 A 31 A	4,0 mm ³ 16,0 mm ³		A1 (P _{PV})	A3 (P _{max,IVV})	consumer		
<u>к</u> к1	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses X1 Fuse from Inverter / MPPT to Battery Pmax (5 see posk load) imma = Pmax(Juystem Add safety margin of 20% X1 Fuse selected X2 Fuses from charge control to Battery ke Add safety margin of 20%. K1 Fuse selected	25,0 mm ⁴ 4mm2 - 20m 16mm2 - 8m 10000 W 208 A 250 A 250 A 250 A 26,00 A 31 A 50 A	4,0 mm ² 16,0 mm ²			A3 (P _{max,INV})	consumer		
<u>к</u> к1 к2	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses K1 Fuse from inverter / MPPT to Battery Pmax (See peak load) Imax = Pmax/Usystem Add safety margin of 20% K1 Fuse selected K2 Fuses from charge control to Battery Ve: Add safety margin of 20% K1 Fuse selected	25,0 mm ¹ 4mm2 - 20m 16mm2 - 8m 10000 W 208 A 250 A 250 A 250 A 250 A 31 A 50 A	4,0 mm ² 16,0 mm ²		A1 (P _{PV})	A3 (P _{mat.NV})	consumer		
<u>к</u> к1 к2	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses K1 Fuses from Inverter / MPPT to Battery Pmax (Ssee paek load) Imax = Pmax/Usystem Add safety margin of 20% K1 Fuse selected K2 Fuses from charge control to Battery te Add safety margin of 20% K1 Fuse selected K3 Fuses selected K3 Fuses from module to charge control	25,0 mm ¹ 4mm2 - 20m 16mm2 - 8m 100000 W 208 A 250 A 250 A 250 A 250 A 31 A 50 A	4,0 mm ² 16,0 mm ²		A1 (P _{PV})	A3 (P _{max,NV})	consumer		
<u>к</u> к1 к2	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses KI Fuse from Inverter / MPPT to Battery Pmax (3 sec peak load) Imax = Pmax/Usystem Add safety margin of 20%. KI Fuse selected K2 Fuses from charge control to Battery tc. Add safety margin of 20%. KI Fuse selected K3 Fuses selected K3 Fuses from module to charge control Bsc. module	25,0 mm ⁴ 4mm2 - 20m 16mm2 - 8m 10000 W 208 A 250 A 250 A 250 A 250 A 31 A 50 A	4,0 mm ² 16,0 mm ²	K3 Fuse	A1 (P _P)	A3 (P _{max,NV})	consumer		
К К К К З	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses K1 Fuse from Inverter / MPPT to Battery Pmax (5 sec peak load) Imax = Pmax/Usystem Add safety margin of 20% K1 Fuse selected K2 Fuses from charge control to Battery kc Add safety margin of 20% K1 Fuse selected K3 Fuses from module to charge control Isc, module Monut of Stings - (mumber of fuses)	25,0 mm ¹ 4mm2 - 20m 16mm2 - 8m 10000 W 208 A 250 A 250 A 250 A 250 A 31 A 50 A 31 A 50 A 2,56 A	4,0 mm ² 16,0 mm ²	K3 Fuse [A1 (P _W)	A3 (P _{max,RV}) A3 (P _{max,RV}) A4	consumer		
К К К К З	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses KI Fuse from Inverter / MPPT to Battery Pmax (3 see peak load) imax = Pmax/Usystem Add safety margin of 20% KI Fuse selected K2 Fuses from charge control to Battery te Add safety margin of 20% KI fuse selected K3	25,0 mm ⁴ 4mm2 - 20m 16mm2 - 8m 10000 W 208 A 250 A 250 A 250 A 250 A 31 A 50 A 9,56 A 2 2 10 A	4,0 mm ² 16,0 mm ²	K3 Fuse	A1 (Pv)	A3 (P _{max,RV}) A3 (P _{max,RV}) A4	consumer		
<u>к</u> к1 к2	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses KI Fuse from Inverter / MPPT to Battery Pmax (5 sec peak load) Imax = Pmax/Usystem Add safety margin of 20% KI Fuse selected K2 Fuses from charge control to Battery kc Add safety margin of 20% KI Fuse selected K3 Fuses from module to charge control Isc, module Amount of Strings - (number of fuses) Isc, PV Generator	25,0 mm ¹ 4mm2 - 20m 16mm2 - 8m 10000 W 208 A 250 A 250 A 250 A 26,000 A 31 A 50 A 9,56 A 2 10A	4,0 mm ² 16,0 mm ²	K3 Fuse	A1 (P _w)	A3 (P _{max,NV})	Consumer		
<u>к</u> к1 к2	Selected Cable selected diameter SOLAR Cable calculated leangth Other Cable Fuses K1 Fuse from Inverter / MPPT to Battery Pmax (5 sec peakload) imax = Fmax/Usystem Add safety margin of 20% K1 Fuse selected K2 Fuses from charge control to Battery kc Add safety margin of 20% K1 Fuse selected K3 F	25,0 mm ³ 4mm2 - 20m 16mm2 - 8m 10000 W 208 A 250 A 250 A 250 A 250 A 31 A 50 A 9,56 A 2 10 A 11 A	4,0 mm ² 16,0 mm ²	КЗ Fuse [A1 (P _{vv})	A3 (P _{max,NV}) A3 (P _{max,NV}) A4 K1 Fuse	consumer		

Figure 81: Typical Design Template - Adama



Self-Check	-	3
		•••

Written Test

Instruction: Follow the below selected instruction

The following are true or false items, write true if the statement is true and write false if the statement is false.

N°	Questions and answers
1	The Bill of Materials should include all material required
	True or false:
2	A design template helps to structure the design process and avoid mistakes
	True or false:

Note: the satisfactory rating is as followed

Satisfactory	2 points
Unsatisfactory	Below 2 points

Answer Sheet	Score =
	Rating:
Name	Date











LAP Test Practi	cal Demonstration

Name:	Date:	
Time started:	Time finished:	

Instructions:

Task 1:



Works Cited

- off-grid europe. (2017). Retrieved from https://www.off-grideurope.com/media/wysiwyg/tutorial images/12VBattery scaled logo OGE.png
- Assoc. Prof. Theocharis Tsoutsos, Z. G. (2011). *Catalogue of common failures and improper practices.* Intelligent Energy Europe.
- Boxwell, M. (2017). Solar Electricity Handbook. Greenstream Publishing Limited.
- Dobelmann, D. J., & Klauss-Vorreiter, A. (2009). *Promotion of the Efficient Use of Renewable Energies in Developing Countries.* DGS e.V. International Solar Energy Society/German Section.
- Hankins, M. (2010). Stand-alone Solar Electric Systems. Earthscan.
- Louie, H. (2018). *Off-Grid Electrical Systems in Developing Countries*. Springer International Publishing.
- Mayfield, R. (2010). *Photovoltaic Design & Installation for Dummies*. Wiley Publishing, Inc.
- Solar4RVs. (n.d.). *choosing-the-right-solar-charge-controller-regulat/*. Retrieved from https://www.solar4rvs.com.au: https://www.solar4rvs.com.au/buying/buyer-guides/choosing-the-right-solar-charge-controller-regulat/









Contents

L	D 1: Ca	alcula	ate Energy Demand	3
1	Listi	ng lo	bad demand in a tabulated form	3
	1.1	Intro	oduction	3
	1.2	Defi	nition of systems and components	4
	1.2.	1	Components	4
	1.2.	2	Systems	5
	1.2.	3	Components	7
	1.3	Pea	k Demand	8
	1.4	Pow	ver and Energy	8
	1.4.	1	Energy	8
	1.4.	2	Power	9
	1.5	Тур	es of off-grid PV systems	9
	1.5.	1	AC Coupled System	10
	1.5.	2	DC Coupled Off-grid PV Systems	
	1.5.3	3	AC Coupled Off-grid PV system	
	1.5.4	4	Efficiency	
	1.6	Loa	d demand table	12
	1.7	DC	Loads	
2	Calo	culat	ing energy demand for each load	17
	2.1	Intro	oduction	17
	2.2	Calo	culate energy demand	17
	2.3	DC	Loads	17
L	D2 Cal	culat	ing System Components	3
1	Dete	ermiı	ning Maximum Depth of Discharge	3
	1.1	Intro	oduction	3
	1.2	Batt	ery overview	4
	1.2.	1	Energy Storage	4
	1.2.	2	Principle of Operation	5
	1.2.	3	Rated Storage Capacity	6
	1.2.4	4	Charge and Discharge	6
	1.2.	5	State of Charge	7
	1.2.	6	Cycles and Cycle Life	7
	1.2.	7	Depth of Discharge	8
	1.2.	8	Solar Batteries	8
	1.3	Det	ermining Depth of Discharge	8
2	Calo	culat	ing Battery capacity	12
	2.1	Intro	oduction	12
	2.2	Calo	culate battery size	12
			Star Philait	as hitch



ADRA



F٧



2.2.1	Energy Consumption	
2.2.2	System efficiency	
2.2.3	System Voltage	
2.2.4	Autonomy	
2.2.5	Depth of Discharge	
2.2.6	Calculation formula	
LO 3 Calcula	ate array size	3
1 Determ	ning minimum solar insolation	3
1.1 Intr	oduction	
1.2 Ba	ckground	
1.2.1	Direct and Diffuse Radiation	5
1.2.2	Solar Irradiance	5
1.2.3	Insolation	6
1.3 Sou	urce of data	
1.3.1	Getting Insolation data from PVGIS	
1.3.2	Getting Insolation Data from Power Data Access Viewer	
1.3.3	Interpreting Insolation Data	
1.4 Ca	culating minimum solar insolation	
2 Calcula	ting array size	
2.1 Intr	oduction	
2.2 Sys	stem losses and efficiency	
2.3 Ca	culating array size	
2.3.1	Determining number of Modules	
3 Adjustir	g array size based on the environmental factors	
3.1 Intr	oduction	
3.2 Env	vironmental factors	
3.2.1	Insolation	
3.2.2	Temperature	
3.2.3	Shading	
3.2.4	Dust	
LO 4: Deterr	nine peak AC load and inverter size	
1 Determ	ning peak ac load demand	
1.1 Intr	oduction	
1.2 Wa	ys of determining the peak load	
1.2.1	Load Table	
1.2.2	Measurement	
2 Calcula	ting inverter size	
2.1 Intr	oduction	
2.2 Sel	ecting inverter	











2.2.1	Matching the peak load	29			
2.2.2	Matching the Battery Voltage	30			
2.2.3	Surge Capabilities	31			
2.2.4	Waveform	31			
2.2.5	Stand-by Mode	31			
2.3 A	dama Design	32			
LO 5: Calo	culate the size of the charge controller/regulator	37			
1 Deter	mining size of the charge controller/regulator	37			
1.1 li	ntroduction	37			
1.1.1	Types of Charge Controllers	38			
1.1.2	Function of a Charge Controller	39			
1.2 F	V Input Voltage Range	40			
1.3 li	nput Current Range	43			
1.4 C	Charge Controller Output Voltage	43			
1.5 C	Charge controller power rating	43			
1.6 F	Protective Devices and other features	43			
1.7 A	dama Design	43			
1.7.1	String design	46			
1.7.2	Charge Controller Dimensioning	47			
1.7.3	Ambient Temperature	47			
1.7.4	Maximum Voltage	48			
1.7.5	Minimum Voltage	49			
1.7.6	Maximum Current	50			
2 Doing	tasks and calculations	52			
2.1 li	ntroduction	52			
2.2 E	Doing tasks according to standard calculations for:	52			
2.2.1	System losses	52			
2.2.2	Wire voltage drop	53			
2.2.3	Site assessment data	55			
3 Reco	rding and documenting calculations in a standard way	57			
3.1 li	ntroduction	57			
3.2 0	Charge Controller Sizing Process	58			
3.2.1	Input Data	58			
3.2.2	Derived Data	58			
3.2.3	Cross-checking the data	59			
3.2.4	Automating the Design Process	60			
LO 6:- Bal	ance of System	65			
1 Deter	mining and calculating size of wires and protection devices, low voltage				
disconnec	lisconnectors, Kilowatt Hour meter and battery meter				







EW



	1.1	Introduction6	5
	1.2	Calculate cable sizes	; 7
	1.2.	1 Type of wire	8
	1.3	Fuses and circuit breakers7	0
	1.3.	1 Battery Fuse Calculation7	2
	1.3.	2 PV Fuse calculation	2
	1.4	Switches	3'
	1.5	Meter selection	3'
	1.5.	1 Adama design7	'5
2	Det	ecting and documenting technical problems8	0
	2.1	Introduction	0
	2.2	Understanding The Environment	0
	2.3	Documenting Technical Problems	51
	2.3.	1 Common Mistakes	2
3	Con	npleting and reporting the work	5
	3.1	Introduction	5
	3.2	Bill of Materials	5
	3.3	Design Calculations	57
W	/orks Cited		









